Monthly Recheck Report

Healthy Homes Standards rechecks | October 2026


13%

Passed


87%

Failed

Recheck outcomes



Reasons for failing



Pass rate 13% | Fail rate 87%

Share of all fail reasons recorded

Key points

- 13% of rechecks passed; 87% failed.
- Draught stopping was the most common reason for failing (44% of fail reasons).
- Insulation degradation or damage (24%) and damaged gutters/ downpipes (20%) were next, then extraction fan issues (8%) and blocked gutters and drains (4%).

HEALTHY HOMES NEW ZEALAND